




Product Service

CERTIFICATE

No. Z2 117654 0007 Rev. 00

Holder of Certificate: **Restar Solar Renewable Energy Co., Ltd.**
No. 30 Yongshun Road, Zhulin Town, Jintan District
213200 Changzhou, Jiangsu Province
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062428702-00

Valid until: 2029-05-26

Date, 2024-06-17


(Zhulin Zhang)

CERTIFICATE

No. Z2 117654 0007 Rev. 00

Model(s):

RT8lxxxM-FB, xxx=530-580 in steps of 5
RT8KxxxM-FB, xxx=445-485 in steps of 5
RT8VxxxM-FB, xxx=400-435 in steps of 5
RT8lxxxM, xxx=530-585 in steps of 5
RT8KxxxM, xxx=445-485 in steps of 5
RT8VxxxM, xxx=400-435 in steps of 5
xxx is standing for rated output power at STC

Parameters:

Fire Safety Class:	Class C according to UL790.
Safety Class:	Class II
Max. System Voltage:	1500V DC
Construction:	Framed, with Junction box, cable and connector.
Dust and Sand Test Method:	Lc1
Dust/sand type:	95% SiO ₂
Dust /sand concentration:	5g/m ³
Testing Air Velocity:	20m/s
Test Duration:	4h/each side

Tested according to:

IEC 61215-1:2021
IEC 61215-1-1:2021
IEC 61215-2:2021
IEC 61730-1:2023
IEC 61730-2:2023
PPP 59022B:2021